


STI-9713



STI-9712

IMPORTANT

Do not attempt to install the guard until the smoke sensor has been tested and in proper working order according to the manufacturer's installation directions furnished with the sensor unit.

OPTIONAL FASTENERS

1. KIT-82 - #8 x 1 1/2" tamper resistant stainless steel screws
2. 19038 tamper resistant bit with 5/16" hex drive

SERVICE

1. Periodic cleaning of the smoke detector is required so dust and other matter does not accumulate.
2. To service the smoke sensor unit, loosen but do not remove the (4) screws, rotate clamps and DRILL (4) .25 in. carefully remove the wire guard.

APPROVALS

DSTI-9713 is UL Listed No. S3504 for use with the following smoke detectors: System Sensor Models 2251, 2251T, 2251B, 2251TB, 2251TM, 2251TMB, 2251BR, 2551, 2551T, FTX-P1, FCI Models ASD-PL, ASD-P, ASD-PH, ASD-PTL, ASD-FILTEREX, ASD-FILTREXF, MCS-ACCLIMATE, ASD-PL2, ASD-PL2F, ASDPTL2, ASD-PTL2F, MCD-ACCLIMATE2, MCS-ACCLIMATE2F, ASD-PL2FR, Secutron Models MR1-2251, MR1-2251B, EST Models 2251F, 2251FB, Mircom Models MIX-2251, MIX-2251B, Intelligent Systems Model ISL 2251, JCI Model 2951J, ADT Model 2951ADT, Fire-Lite Model SD355, Gamewell Model SS-P, Honeywell Models TC806B1076, TC806B1001 under 300 Fpm, Notifier Model FSP-751.

Three year warranty or a one year limited warranty (from date of purchase) on most products. See website for details. Electronic warranty form at www.sti-usa.com/wc14.

INSTALLATION OF STI-9713 & STI-9712 STEEL WEB STOPPER FOR PHOTOELECTRIC SMOKE DETECTOR

All specifications and information shown were current as of publication and are subject to change without notice.

9712_13IS FEB2017

